

TEST CERTIFICATE

ST-13-11-04-01

Product: Variant 3: Flooring profiles with digitally printed surface
and high abrasion coating, AC3

Producer: Küberit Profile Systems GmbH & Co. KG
Römerweg 9
58513 Lüdenscheid
Deutschland / Germany

Order /

Test methods: Determination of the resistance against abrasion according to EN 13329

Test report: 278153

Test result:

The tested product can be assessed / classified for the abrasion resistance in accordance to EN 13329 as follows:

Variant	Property	Result	Classification in level of use (LU) according to EN 13329
3	Resistance against abrasion	Abrasion class AC3	LU 21 - 23 and 31 are fulfilled

Dresden, 06 November 2013



Head of laboratory




Engineer in charge